

**BEFORE THE  
PUBLIC SERVICE COMMISSION  
OF MARYLAND**

In the Matter of the )  
Application of Catoctin Power, LLC )  
for a Certificate of Public Convenience and ) Case No. 8997  
Necessity To Construct a 600 MW Generating )  
Facility in Frederick County, Maryland )

**DIRECT TESTIMONY OF WILLIAM V. PAUL**

1 **Q. PLEASE STATE YOUR NAME, OCCUPATION, AND CURRENT**  
2 **POSITION.**

3 A. My name is William V. Paul, and I am the Chief of the Combustion  
4 and Metallurgical Division of the Air and Radiation Management  
5 Administration (ARMA), Maryland Department of the Environment  
6 (MDE). My resume is appended to this testimony as Appendix A.

7 **Q. PLEASE DESCRIBE YOUR SPECIFIC PROFESSIONAL**  
8 **EXPERIENCE WHICH IS RELEVANT TO YOUR**  
9 **RESPONSIBILITIES ON THIS PROJECT.**

10 A. I have more than 25 years of experience in air pollution control,  
11 including 19 years with ARMA and 8 years with an air pollution  
12 control equipment manufacturing firm. As Chief of the Combustion  
13 and Metallurgical Division of ARMA, I have primary responsibility for  
14 new source review of major stationary sources subject to Federal  
15 Prevention of Significant Deterioration (PSD) and nonattainment New  
16 Source Review (NA-NSR) requirements. I have participated in the  
17 NA-NSR and/or PSD review of most of the major power plants that  
18 have been proposed for construction in Maryland in the last fifteen  
19 years. These include Mirant Mid-Atlantic’s Chalk Point Expansion  
20 and Dickerson Expansion projects, Orion Power Holding’s Kelson  
21 Ridge Facility in Charles County, Old Dominion Electric

1 Cooperative/Reliant Energy Power Generation, Inc.,  
2 (ODEC/Reliant's) Rock Springs power plant, Delmarva Power and  
3 Light Company's Dorchester plant, Applied Energy Services' (AES)  
4 Warrior Run plant, Panda Energy Corporation's Brandywine plant,  
5 Baltimore Gas and Electric Company's Perryman plant, the Potomac  
6 Electric Power Company's Station H and Chalk Point plants, the  
7 Southern Maryland Electric Cooperative turbine project, and the  
8 Montgomery County Resource Recovery Facility.

9 **Q. WHAT WERE YOUR RESPONSIBILITIES WITH RESPECT TO**  
10 **THE STATE'S ENVIRONMENTAL REVIEW OF CATOCTIN**  
11 **POWER'S PROJECT?**

12 A. On behalf of ARMA, I reviewed the PSD application for the Catoctin  
13 Power, LLC (Catoctin Power) project with regard to compliance with  
14 applicable Federal and State air quality regulations.

15 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

16 A. The purpose of my testimony is to convey the results of my review of  
17 the recommended air quality conditions for Catoctin Power and  
18 ascertain whether they meet State and Federal requirements. My  
19 testimony is based on information contained in the applicant's CPCN  
20 application and the document prepared by the Maryland Department  
21 of Natural Resources Power Plant Research Program (PPRP) titled  
22 *Environmental Review of the Proposed Catoctin Power Project* (DNR  
23 Exhibit \_\_ (DHB-2A)).

24 **Q. PLEASE SUMMARIZE THE SOURCES OF INFORMATION USED**  
25 **IN YOUR REVIEW.**

26 A. I reviewed Catoctin Power's application for a Certificate of Public  
27 Convenience and Necessity (CPCN) dated February 25, 2004, and  
28 subsequent Responses to Data Requests prepared by Catoctin Power.  
29 In particular, I reviewed the sections of the CPCN application and  
30 other documents dealing with emissions control options, net emission

1 increases, and the determination of Best Available Control Technology  
2 (BACT) and Lowest Achievable Emission Rate (LAER).

3 *Operations*

4 **Q. WHAT, GENERALLY, ARE THE AIR EMISSIONS SOURCES**  
5 **THAT CATOCTIN POWER IS PROPOSING TO CONSTRUCT**  
6 **AND OPERATE AS A PART OF THE PROPOSED PROJECT?**

7 A. Catoctin Power is proposing to construct and operate two General  
8 Electric Frame 7FA combustion turbines (CTs) to be operated in  
9 combined cycle mode, burning pipeline quality natural gas as the sole  
10 fuel. Each CT will be equipped with a heat recovery steam generator  
11 (HRSG) with duct burners. The duct burners will provide additional  
12 steam supply, enabling higher power output when needed. Steam  
13 produced by the HRSGs will be combined and directed to a steam  
14 turbine. The facility will have a nominal electric generating capacity of  
15 600 megawatts (MW). The CTs will be designed with dry low-NO<sub>x</sub>  
16 combustors. The duct burners will be equipped with low-NO<sub>x</sub>  
17 burners. Catoctin Power will operate selective catalytic reduction  
18 (SCR) systems downstream of the duct burners using 19 percent  
19 aqueous ammonia to control nitrogen oxides (NO<sub>x</sub>) emissions. The  
20 CTs and duct burners will be equipped with catalytic oxidation  
21 systems to control carbon monoxide (CO) and volatile organic  
22 compounds (VOCs).

23 In addition to the CTs, the Catoctin Power project will also include the  
24 installation and operation of one 1,000-kilowatt (kW) emergency diesel  
25 generator (EDG) at the plant, one 350-kW EDG at the offsite pump  
26 house, and one 370-horsepower (hp) emergency firewater pump. The  
27 facility will be equipped with a multi-cell mechanical draft cooling  
28 tower with drift eliminators. Catoctin Power will also install one  
29 aqueous ammonia storage tank (approximately 20,000 gallons)  
30 associated with the SCR system, and two electric-powered fuel gas  
31 heaters.

1 **Q. WILL THERE BE RESTRICTIONS ON THE OPERATION OF ANY**  
2 **OF THE PROPOSED EMISSIONS SOURCES?**

3 A. Yes. Catoctin Power proposes to operate each of the CTs for 24 hours  
4 per day, 365 days per year (8,760 hours per year); however, duct  
5 burner heat input will be limited to 577 million British thermal units  
6 hour per (MMBtu/hr, higher heating value) per unit at 90°F (or 561  
7 MMBtu/hr at 54°F). Catoctin Power proposes to restrict duct firing to  
8 a maximum of 4,000 hours per year per unit.

9 Catoctin Power has indicated that both the plant and pump house  
10 EDGs will only be operated in the event of a disruption in power  
11 delivery and during testing, and for no more than 200 hours per year  
12 each. Similarly, Catoctin Power proposes to limit operation of the  
13 firewater pump engine to a maximum of 100 hours per year, which  
14 would include operations for monthly testing and maintenance.

15 *Location*

16 **Q. WHAT IS THE PROPOSED LOCATION OF THE CATOCTIN**  
17 **POWER PROJECT?**

18 A. The Catoctin Power facility will be located on a 20-acre tract of land in  
19 Frederick County, Maryland, within the confines of the 2,200-acre  
20 Eastalco Works industrial complex.

21 *PSD and Nonattainment New Source Review Background*

22 **Q. WHAT IS A “NATIONAL AMBIENT AIR QUALITY**  
23 **STANDARD?”**

24 A. The U.S. EPA has established allowable ambient concentration levels  
25 for six so-called “criteria pollutants”, namely, carbon monoxide (CO),  
26 nitrogen dioxide (NO<sub>2</sub>), sulfur dioxide (SO<sub>2</sub>), particulate matter (PM),  
27 lead, and ozone. Concentration levels for PM have been established  
28 separately for two particle size ranges: less than 10 microns in diameter  
29 (PM<sub>10</sub>), and less than 2.5 microns in diameter (PM<sub>2.5</sub>). The

1 concentration levels, called the National Ambient Air Quality  
2 Standards (NAAQS), are designed to protect public health and  
3 welfare, with an adequate margin of safety. Of the criteria pollutants,  
4 ozone is the only one that is not emitted directly by sources of air  
5 pollution. Ozone is formed in the atmosphere, primarily on hot  
6 summer days, from several precursor pollutants including VOCs and  
7 NO<sub>x</sub>. VOCs do not have ambient standards *per se*; rather, VOC  
8 emissions are regulated as precursors to ozone formation. NO<sub>x</sub>  
9 emissions are also regulated as ozone precursors, in addition to being  
10 regulated as the criteria pollutant NO<sub>2</sub>.

11 **Q. PLEASE EXPLAIN THE TERMS “PREVENTION OF SIGNIFICANT**  
12 **DETERIORATION (PSD)” AND “NONATTAINMENT NEW**  
13 **SOURCE REVIEW (NA-NSR).”**

14 A. PSD refers to a set of regulations intended to apply in attainment areas,  
15 which are areas of the country that are currently meeting the NAAQS  
16 for a given pollutant. The PSD regulations contain requirements for  
17 new and modified sources that emit pollutants above a significant  
18 emissions threshold. The pollutant-specific thresholds are defined in  
19 the regulations and are expressed as tons per year. The PSD  
20 regulations contain both control technology and ambient impact  
21 requirements. Generally, the control technology requirement for PSD  
22 sources is to ensure that emissions are controlled to a level  
23 representing the Best Available Control Technology (BACT). The  
24 ambient impact requirement is that emissions from the source produce  
25 impacts that are less than the PSD increments (allowable incremental  
26 increases in ambient pollution levels), and that the source not cause or  
27 contribute to nonattainment of the NAAQS. Compliance with the PSD  
28 ambient requirements is evaluated through the use of air quality  
29 dispersion models, applied in accordance with guidance established by  
30 the U.S. EPA modeling guidelines.

31 NA-NSR is a set of regulations that applies to areas that are not  
32 meeting the NAAQS. Sources subject to NA-NSR must apply a level  
33 of control technology that represents the Lowest Achievable Emission

1 Rate (LAER). Sources subject to NA-NSR must also secure “emissions  
2 reductions” or “offsets” at a ratio sufficient to demonstrate a positive  
3 net air quality benefit from the project. In Maryland, emission offsets  
4 must be established as federally enforceable prior to the issuance of a  
5 construction permit or approval for a NA-NSR source. Dispersion  
6 modeling, particularly for ozone, is not generally required for NA-  
7 NSR.

8 **Q. PLEASE DEFINE “BACT” AND “LAER.”**

9 A. Best Available Control Technology, or BACT, is defined as an  
10 emissions limitation, determined on a case-by-case basis, which  
11 provides for the maximum degree of reduction of a pollutant, taking  
12 into account energy, environmental, and economic impacts and other  
13 costs. The “case-by-case” process of determining BACT is a dynamic  
14 one, which encourages tightening of emissions control requirements as  
15 the effectiveness of control technologies improve over time. At a  
16 minimum, BACT must be at least as stringent as any applicable,  
17 established New Source Performance Standards (NSPS), found in 40  
18 CFR Part 60.

19 Lowest Achievable Emission Rate, or LAER, is defined as the more  
20 stringent of either: (1) the most stringent emissions limitation which is  
21 contained in the implementation plan of any state for a class or  
22 category of stationary sources, unless the owner or operator of the  
23 proposed stationary source demonstrates that these limitations are not  
24 achievable; or (2) the most stringent emissions limitation which is  
25 achieved in practice by a class or category of stationary sources. LAER  
26 is always at least as stringent as BACT.

27 **Q. WHAT ARE THE POLLUTANTS OF CONCERN FOR THE**  
28 **STATE’S ANALYSIS OF THE CATOCTIN POWER PROJECT?**

29 A. All pollutants regulated under the Clean Air Act are subject to review.  
30 This includes the criteria pollutants (which are those for which

1 NAAQS have been established), as well as hazardous air pollutants  
2 (HAPs).

3 *PSD and NA-NSR Applicability*

4 **Q. DID THE STATE EVALUATE THE CPCN APPLICATION AND**  
5 **MAKE A DETERMINATION REGARDING THE APPLICABILITY**  
6 **OF THE PSD AND NONATTAINMENT NSR PERMITTING**  
7 **PROGRAMS?**

8 A. Yes. Regarding PSD, as discussed in Section 4.3 of the *Environmental*  
9 *Review of the Proposed Catoctin Power Project* (DNR Exhibit \_\_ (DHB-  
10 2A)), potential emissions of NO<sub>2</sub>, CO, SO<sub>2</sub>, and PM<sub>10</sub> from the Catoctin  
11 Power project will exceed significance thresholds and are therefore  
12 subject to PSD review. Emissions of other regulated pollutants,  
13 including lead, total fluorides, total reduced sulfur, reduced sulfur  
14 compounds, hydrogen sulfide, mercury, beryllium, arsenic, asbestos,  
15 vinyl chloride, chlorofluorocarbons (CFCs), halons, and radionuclides  
16 will be zero or negligible.

17 Regarding NA-NSR, potential emissions of NO<sub>x</sub> and VOCs will be  
18 above applicable thresholds and so trigger NA-NSR requirements.

19 **Q. WAS THE PROJECT EVALUATED AS A NEW MAJOR SOURCE**  
20 **POTENTIALLY SUBJECT TO PSD AND NA-NSR, OR AS A**  
21 **“MODIFICATION” TO AN EXISTING MAJOR SOURCE?**

22 A. As mentioned above, the proposed Catoctin Power project is a new  
23 major source of pollutants under the PSD and NA-NSR programs and  
24 so is subject to PSD and NA-NSR review. However, because the  
25 proposed facility will be located within the confines of an existing  
26 major source (Eastalco), the State investigated whether the Catoctin  
27 Power project would be considered part of the Eastalco “source” for  
28 PSD purposes, and thus whether the Catoctin Power project would be  
29 a “modification to an existing major stationary source.”

30 **Q. WHAT IS THE DEFINITION OF “SOURCE” FOR PSD PURPOSES?**

1 A. Under 40 CFR 52.21 and COMAR 26.11.06.14, "stationary source" is  
2 defined in the PSD regulations (specifically at 40 CFR 52.21(b)(5)) as  
3 "...any building, structure, facility, or installation which emits or may  
4 emit a regulated NSR pollutant." The term "building, structure,  
5 facility or installation" is defined in 40 CFR 52.21(b)(6) as:

6 "...all of the pollutant-emitting activities which belong to the same  
7 industrial grouping, are located on one or more contiguous or adjacent  
8 properties, and are under the control of the same person (or persons  
9 under common control) except the activities of any vessel. Pollutant-  
10 emitting activities shall be considered as part of the same industrial  
11 grouping if they belong to the same "Major Group" (i.e., which have the  
12 same first two digit code) as described in the Standard Industrial  
13 Classification Manual, 1972, as amended by the 1977 Supplement (U.S.  
14 Government Printing Office stock numbers 4101-0066 and 003-005-00176-  
15 0, respectively)."

16 **Q. WHAT FACTORS DID YOU CONSIDER IN DETERMINING**  
17 **WHETHER THE PROPOSED CATOCTIN POWER PROJECT IS**  
18 **CONSIDERED PART OF THE EXISTING EASTALCO SOURCE,**  
19 **OR ITS OWN, SEPARATE STATIONARY SOURCE?**

20 A. We reviewed information presented by the Applicant in its CPCN  
21 application and in its Response to DNR Data Request #1, and guidance  
22 documents available from the U.S. EPA. Guidance from the U.S. EPA  
23 on this issue of "source" indicates that the underlying criteria that  
24 would cause the power plant to be considered part of the Eastalco  
25 aluminum facility would be that the power plant: 1) belongs to the  
26 same industrial grouping as Eastalco (or is considered a support  
27 facility); 2) is adjacent to Eastalco; and 3) is under "common control."

28 **Q. WHAT WERE THE FINDINGS IN THIS CASE REGARDING**  
29 **THESE THREE CRITERIA ?**

30 A. Regarding the first criterion, the proposed Catoctin Power facility (SIC  
31 4911) is not part of the same industrial grouping as Eastalco (SIC 3334),

1 nor does either facility serve as a “support” facility to the other. In  
2 Response to DNR Data Request #1, Catoctin Power indicated that “the  
3 Power Plant has no obligation to sell electricity, heat or steam to the  
4 Aluminum Smelter, and the Aluminum Smelter has no obligation to  
5 purchase electricity, heat or steam from the Power Plant.” Eastalco will  
6 not store or convey Catoctin Power’s electricity, nor will the power  
7 plant obtain its fuel from Eastalco. Catoctin Power does intend to  
8 share the existing Eastalco septic system and substation “as a matter of  
9 convenience.”

10 Regarding the second criterion, the Catoctin site is clearly “adjacent to”  
11 Eastalco, as it lies within the Eastalco property boundary.

12 The third criterion, related to the issue of “common control” is more  
13 complicated in this case. Based on information from the Applicant in  
14 response to DNR Data Request #1 of 23 April 2004 (a copy of which is  
15 included in *Environmental Review of the Proposed Catoctin Power Project*  
16 (DNR Exhibit \_\_ (DHB-2A)), Catoctin Power is a wholly-owned  
17 subsidiary of Sempra Energy Resources. The “Eastalco” smelter is  
18 owned by Eastalco Aluminum Company (which is a wholly-owned  
19 subsidiary of Alumax, Inc., which is a wholly-owned subsidiary of  
20 Alcoa, Inc., Mitalco, Inc., and Alumerica, Inc.). Catoctin Power intends  
21 to lease property from Eastalco to operate the power plant.

22 At present, Eastalco does not own any portion of Catoctin Power, nor  
23 does Catoctin Power own any portion of the aluminum operations.  
24 Catoctin Power reports that neither entity has decision-making  
25 authority over the other, nor have the parties “entered into any service  
26 contracts that make one entity dependent on the other entity”  
27 (Attachment 1 to Response to DNR Data Request #1).

28 However, Eastalco has an option to purchase up to 50 percent of  
29 Catoctin Power. In Response to DNR Data Request #1, Catoctin Power  
30 indicates that “Eastalco cannot exercise its option until after all permit  
31 approvals have been obtained and other contractual obligations are  
32 met. At that point, Eastalco will have 90 days to exercise its option.”

1 **Q. HAS THIS ISSUE BEEN RESOLVED?**

2 A. Yes, this issue has been resolved to ARMA's satisfaction. PPRP and  
3 ARMA have reviewed the information provided by the applicant and  
4 EPA and other guidance documents, and have concluded that the two  
5 co-located facilities constitute two separate sources for PSD purposes.  
6 We addressed this issue with U.S. EPA Region III during the course of  
7 the review of the application. EPA indicates that should Eastalco  
8 exercise its option to acquire a portion of Catoctin Power before the  
9 power plant "commences construction" then the determination of  
10 "source" must be revisited (this correspondence from U.S. EPA is also  
11 included in PPRP's *Environmental Review of the Proposed Catoctin Power*  
12 *Project* (DNR Exhibit \_\_ (DHB-2A)).

13 *PSD Requirements: BACT Determination*

14 **Q. WHICH OF CATOCTIN POWER'S EMISSIONS SOURCES ARE**  
15 **SUBJECT TO BACT REVIEW?**

16 A. All emissions units that are part of the project and that have the  
17 potential to emit NO<sub>2</sub>, CO, SO<sub>2</sub>, and/or PM (including PM10) are  
18 subject to BACT review. These emissions units include the CTs, the  
19 cooling tower, the emergency diesel generators, and the firewater  
20 pump engine.

21 **Q. PLEASE SUMMARIZE CATOCTIN POWER'S BACT PROPOSAL**  
22 **FOR THE COMBUSTION TURBINES.**

23 A. For NO<sub>2</sub>, Catoctin Power is proposing the exclusive use of pipeline  
24 quality natural gas, operation of advanced dry low-NO<sub>x</sub> (DLN)  
25 combustion design, low-NO<sub>x</sub> burners on the duct burners, and  
26 implementation within the HRSG of a control technology known as  
27 selective catalytic reduction (SCR) to achieve a NO<sub>x</sub> emission rate of 2.0  
28 parts per million by volume on a dry weight basis (ppmvd), corrected  
29 to 15 percent oxygen, without duct firing and 2.5 ppmvd when duct  
30 firing, both on a 1-hour average basis.

1 For CO, Catoctin Power is proposing to limit CO emissions through  
2 use of the dry low-NO<sub>x</sub> combustor design, good combustion practices,  
3 and application of an oxidation catalyst system to achieve an emission  
4 rate of 2.0 ppmvd corrected to 15 percent oxygen over a 3-hour  
5 averaging period without duct firing, and 3.0 ppmvd at 15% oxygen on  
6 a 3-hour average basis with duct firing.

7 For SO<sub>2</sub>, Catoctin Power is proposing to use pipeline quality natural  
8 gas with a maximum sulfur content of 1 grain per 100 standard cubic  
9 feet, resulting in a maximum SO<sub>2</sub> emission rate of 6.7 pounds per hour.

10 For PM, including PM<sub>10</sub>, BACT will be achieved by the exclusive use  
11 of pipeline quality natural gas with typical heat content of  
12 approximately 20,500 Btu/lb (lower heating value) and a maximum  
13 sulfur content of 1 grain per 100 standard cubic foot. This will result in  
14 a maximum PM emission rate from the CTs of 21.1 pound per hour on  
15 a 3-hour average basis.

16 **Q. DO YOU CONCUR WITH CATOCTIN POWER'S CONCLUSIONS**  
17 **REGARDING BACT FOR THE COMBUSTION TURBINES?**

18 A. Yes.

19 **Q. PLEASE SUMMARIZE CATOCTIN POWER'S BACT PROPOSAL**  
20 **FOR THE EMERGENCY DIESEL GENERATORS.**

21 A. For both the 1,000-kW plant EDG and the 350-kW pump house EDG,  
22 Catoctin Power is proposing that BACT for all pollutants will be  
23 achieved by the construction and operation of EPA Tier 1-rated  
24 generators burning low sulfur (0.05% sulfur by weight) diesel fuel,  
25 operating for no more than 200 hours per year. The specific emission  
26 rates are summarized in Table 4-10 of the *Environmental Review of the*  
27 *Proposed Catoctin Power Project* (DNR Exhibit \_\_ (DHB-2A)).

28 **Q. DO YOU CONCUR WITH CATOCTIN POWER'S CONCLUSIONS**  
29 **REGARDING BACT FOR THE EMERGENCY DIESEL**  
30 **GENERATORS?**

1 A. Yes.

2 **Q. PLEASE SUMMARIZE CATOCTIN POWER'S BACT PROPOSAL**  
3 **FOR THE FIREWATER PUMP ENGINE.**

4 A. Catoctin Power is proposing that BACT for all pollutants will be  
5 achieved by the construction and operation of a 370-hp engine and  
6 operating the unit for no more than 100 hours per year. The specific  
7 emission rates are summarized in Table 4-10 of the *Environmental*  
8 *Review of the Proposed Catoctin Power Project* (DNR Exhibit \_\_ (DHB-  
9 2A)).

10 **Q. DO YOU CONCUR WITH CATOCTIN POWER'S CONCLUSIONS**  
11 **REGARDING BACT FOR THE FIREWATER PUMP ENGINE?**

12 A. Yes.

13 **Q. PLEASE SUMMARIZE CATOCTIN POWER'S BACT PROPOSAL**  
14 **FOR THE COOLING TOWER.**

15 A. Catoctin Power is proposing to use high efficiency drift eliminators at  
16 the cooling tower to achieve a drift loss rate of 0.0005 percent of  
17 recirculating water flow, resulting in maximum PM emissions of 2.81  
18 pounds per hour and maximum PM10 emissions of 0.71 pounds per  
19 hour (24-hour average basis).

20 **Q. DO YOU CONCUR WITH CATOCTIN POWER'S CONCLUSIONS**  
21 **REGARDING BACT FOR THE COOLING TOWER?**

22 A. Yes, high efficiency drift eliminators are consistent with BACT for this  
23 type of source.

24 **PSD: Ambient Impact Assessment**

25 **Q. BESIDES BACT, ARE THERE OTHER REQUIREMENTS FOR**  
26 **SOURCES SUBJECT TO PSD?**

1 A. Yes, in addition to BACT, sources subject to PSD must conduct impact  
2 analyses to ensure that emissions from the project do not result in  
3 unacceptable impacts to air quality. The impact assessments are  
4 typically conducted through the use of air quality dispersion models.

5 **Q. WAS CATOCTIN POWER'S AIR QUALITY MODELING**  
6 **ANALYSIS CONSISTENT WITH EPA GUIDANCE?**

7 A. Yes. Catoctin Power's air quality modeling analysis was consistent  
8 with EPA's Guideline on Air Quality Models (GAQM), which is  
9 contained in Appendix W to the PSD regulations, 40 CFR Part 51.

10 **Q. PLEASE EXPLAIN THE CONCEPT OF A SIGNIFICANT IMPACT**  
11 **LEVEL (SIL).**

12 A. Significant Impact Levels (SILs) are established for some criteria  
13 pollutants by EPA to serve as initial impact thresholds. These  
14 thresholds, normally just a few percent of the NAAQS, have an  
15 important function, namely, to identify a level of impact that signifies  
16 that further air quality analysis is not necessary. Through air quality  
17 modeling, a source's maximum ambient impact is identified; if the  
18 maximum impact is less than the SIL for all applicable pollutants, the  
19 source is considered to meet all requirements relative to PSD  
20 increments and NAAQS without conducting any further analysis.

21 **Q. PLEASE SUMMARIZE THE RESULTS OF THE STATE'S**  
22 **AMBIENT AIR QUALITY AND PSD IMPACT ANALYSES.**

23 A. Under State and Federal regulations, ambient impacts of NO<sub>2</sub>, SO<sub>2</sub>,  
24 CO, and PM<sub>10</sub> were evaluated against NAAQS and/or PSD SILs  
25 through computer air dispersion modeling. As summarized in Table  
26 4-14 of the Catoctin Power ERD (DNR Exhibit \_\_ (DHB-2A)), and as  
27 described in more detail by Mr. Mark Garrison in testimony in this  
28 case, the maximum impacts for all pollutants of concern and for all  
29 relevant averaging periods are less than applicable SILs.

1           Because the maximum impacts are less than the SILs for all pollutants,  
2           no additional steps need to be taken to demonstrate compliance with  
3           PSD increments and NAAQS for any regulated pollutant.

4    ***NA-NSR Requirements: LAER***

5    **Q.    WHICH OF CATOCTIN POWER'S EMISSIONS SOURCES ARE**  
6    **SUBJECT TO LAER REVIEW AND FOR WHICH POLLUTANTS?**

7    A.    All emissions units that are part of the project with the potential to  
8           emit NO<sub>x</sub> and/or VOCs are subject to LAER review in this case. These  
9           emissions units include the CTs, the emergency diesel generators, and  
10          the firewater pump engine.

11   **Q.    DID YOU REVIEW THE APPLICANT'S LAER ASSESSMENTS**  
12   **FOR NO<sub>x</sub> FROM AFFECTED SOURCES?**

13   A.    Yes. Table 4-22 of the *Environmental Review of the Proposed Catoctin*  
14          *Power Project* (DNR Exhibit \_\_ (DHB-2A)) summarizes the applicant's  
15          proposed LAER for the project.

16   **Q.    PLEASE DESCRIBE THE APPLICANT'S LAER PROPOSAL FOR**  
17   **NO<sub>x</sub> FROM THE COMBUSTION TURBINES.**

18   A.    As described by Julie B. Ross in testimony in this case, Catoctin Power  
19          initially proposed in its CPCN application to use GE combustion  
20          turbines that incorporate advanced dry low-NO<sub>x</sub> (DLN) combustor  
21          technology, dry low-NO<sub>x</sub> burners on the duct burners, and operation  
22          of a selective catalytic reduction (SCR) system to be located within the  
23          heat recovery steam generator (HRSGs) to achieve a NO<sub>x</sub> emission rate  
24          of 2.5 parts per million by volume on a dry weight basis (ppmvd)  
25          corrected to 15% oxygen. ARMA and PPRP reviewed available  
26          literature, EPA databases, and information on other recent combustion  
27          turbine projects and determined that a rate of 2.0 ppmvd corrected to  
28          15% oxygen, rather than 2.5 ppmvd as proposed by Catoctin Power,  
29          would be achievable on these units.

1 Catoctin Power subsequently agreed with this assessment, and in  
2 response to DNR Data Request #4, revised its LAER emissions  
3 estimates, and now indicates that the maximum NO<sub>x</sub> emission rate will  
4 be 2.0 ppmvd corrected to 15% oxygen, based on a 1-hour average  
5 when not duct firing, and 2.5 ppmvd when duct firing.

6 **Q. DO YOU CONCUR WITH THE APPLICANT'S LAER PROPOSAL**  
7 **FOR NO<sub>x</sub> FROM THE COMBUSTION TURBINES?**

8 A. Yes.

9 **Q. PLEASE DESCRIBE THE APPLICANT'S LAER PROPOSAL FOR**  
10 **NO<sub>x</sub> FROM THE EMERGENCY DIESEL GENERATORS.**

11 A. Catoctin Power originally proposed certain NO<sub>x</sub> emission rates for the  
12 plant emergency diesel generator (EDG); however, ARMA and PPRP  
13 determined that lower emission rates were achievable from such a  
14 unit. Therefore, the applicant revised its LAER proposal at the request  
15 of the State and clarified in Response to DNR Data Request #4 of 23  
16 July 2004 that maximum NO<sub>x</sub> emissions from the unit would not  
17 exceed 20.4 lb/hr (or 6.9 grams per brake-horsepower-hour, g/bhp-hr)  
18 on a 3-hour average basis, to be achieved by use of a EPA Tier 1-rated  
19 engine, application of good combustion practices, and limiting  
20 operations to no more than 200 hr/year. Catoctin Power is proposing  
21 use of a Tier 1-rated engine for the 350-kW EDG at the pump house, to  
22 achieve a NO<sub>x</sub> rate of 6.9 g/bhp-hr, or 7.1 lb/hr (3-hour average basis).

23 **Q. DO YOU CONCUR WITH THE APPLICANT'S LAER PROPOSAL**  
24 **FOR NO<sub>x</sub> FROM THE EMERGENCY DIESEL GENERATORS?**

25 A. Yes.

26 **Q. PLEASE DESCRIBE THE APPLICANT'S LAER PROPOSAL FOR**  
27 **NO<sub>x</sub> FROM THE FIREWATER PUMP ENGINE.**

28 A. Catoctin Power has proposed LAER for the firewater pump engine as a  
29 NO<sub>x</sub> emission rate not to exceed 11.5 lb/hr on a 3-hour average basis to

1 be achieved by limiting operations to no more than 100 hr/yr and  
2 application of good combustion practices.

3 **Q. DO YOU CONCUR WITH THE APPLICANT'S LAER PROPOSAL**  
4 **FOR NO<sub>x</sub> FROM THE FIREWATER PUMP ENGINE?**

5 A. Yes.

6 **Q. DID YOU ALSO REVIEW THE APPLICANT'S LAER**  
7 **ASSESSMENTS FOR VOLATILE ORGANIC COMPOUNDS**  
8 **(VOCs) FROM AFFECTED SOURCES?**

9 A. Yes.

10 **Q. PLEASE DESCRIBE THE APPLICANT'S LAER PROPOSAL FOR**  
11 **VOC FROM THE COMBUSTION TURBINES.**

12 A. Catocin Power is proposing as LAER for VOCs to use good  
13 combustion practices and operation of oxidation catalyst systems to be  
14 located within the HRSGs to achieve a maximum VOC emission rate of  
15 0.7 ppmvd, corrected to 15 percent oxygen, on a 3-hr average basis  
16 without duct firing, and 1.3 ppmvd, corrected to 15 percent oxygen, on  
17 a 3-hr average basis with duct firing.

18 **Q. DO YOU CONCUR WITH THE APPLICANT'S LAER PROPOSAL**  
19 **FOR VOC FROM THE COMBUSTION TURBINES?**

20 A. Yes.

21 **Q. PLEASE DESCRIBE THE APPLICANT'S LAER PROPOSAL FOR**  
22 **VOCs FROM THE EMERGENCY DIESEL GENERATORS.**

23 A. Catocin Power originally proposed certain VOC emission rates from  
24 the plant EDG; however, similar to the NO<sub>x</sub> issue described  
25 previously, ARMA and PPRP determined that lower emission rates  
26 were achievable from such a unit. Therefore, the applicant revised its  
27 LAER proposal at the request of the State and clarified in Response to  
28 DNR Data Request #4 of 23 July 2004 that the emergency diesel

1 generator will meet Tier 1 emissions standards. Therefore, LAER for  
2 VOCs from the plant EDG will be a limit of 1.5 lb/hr on a 3-hr average  
3 basis to be achieved by application of good combustion practices and  
4 limiting operations to no more than 200 hr/year. A Tier 1-rated engine  
5 will also be employed for the pump house EDG, to achieve a  
6 maximum VOC rate of 0.5 lb/hr (3-hr average basis).

7 **Q. DO YOU CONCUR WITH THE APPLICANT'S LAER PROPOSAL**  
8 **FOR VOCs FROM THE EMERGENCY DIESEL GENERATORS?**

9 A. Yes. These rates are within the range of known emissions limits for  
10 VOCs from similar sources having undergone LAER or BACT review.

11 **Q. PLEASE DESCRIBE THE APPLICANT'S LAER PROPOSAL FOR**  
12 **VOCs FROM THE FIREWATER PUMP ENGINE.**

13 A. Catoctin Power proposed that LAER for the firewater pump for VOCs  
14 is a limit of 0.91 lb/hr on a 3-hour average basis to be achieved by  
15 application of good combustion practices and limiting operations to no  
16 more than 100 hr/year.

17 **Q. DO YOU CONCUR WITH THE APPLICANT'S LAER PROPOSAL**  
18 **FOR VOCs FROM THE FIREWATER PUMP ENGINE?**

19 A. Yes. The proposed VOC emission rate for the firewater pump engine  
20 is within the range of reported rates for similar units.

21 *NA-NSR Requirements: Other Requirements*

22 **Q. BESIDES APPLICATION OF LAER, ARE THERE ANY OTHER**  
23 **REQUIREMENTS FOR SOURCES SUBJECT TO**  
24 **NONATTAINMENT NSR?**

25 A. Yes. Major new sources of NO<sub>x</sub> in ozone nonattainment areas must 1)  
26 obtain sufficient emissions reductions ("offsets") prior to issuance of a  
27 construction permit; 2) certify that all other sources owned by the  
28 Applicant in the State are complying with all applicable requirements  
29 of the Clean Air Act; and 3) demonstrate that the benefits of the

1 proposed source outweigh the environmental and social costs imposed  
2 as a result of its location, construction, or modification, by conducting  
3 an “alternatives analysis.”

4 **Q. WILL CATOCTIN POWER BE REQUIRED TO SECURE**  
5 **EMISSIONS OFFSETS FOR THE PROJECT, AND IF SO, HOW**  
6 **MANY OFFSETS WILL BE REQUIRED?**

7 A. Yes. The Applicant must secure NO<sub>x</sub> and VOC offsets for each  
8 potential ton of these pollutants to be emitted by the entire project at a  
9 ratio of 1.3 to 1. Projected potential NO<sub>x</sub> emissions from the Catoctin  
10 Power project are 191.7 tons per year; therefore, the proposed Catoctin  
11 Power facility requires 249 tons of NO<sub>x</sub> emissions offsets. Projected  
12 potential VOC emissions from the project are 30tons per year, which  
13 means that the proposed Catoctin Power facility requires 39 tons of  
14 VOC emissions offsets.

15 **Q. MUST THE EMISSIONS OFFSETS ORIGINATE FROM SOURCES**  
16 **WITHIN MARYLAND?**

17 A. No. Under Maryland regulations, offsets may be obtained from  
18 sources within the ozone nonattainment area in which the proposed  
19 facility will be located, or from another ozone nonattainment area, if  
20 the other area has an equal or higher nonattainment classification than  
21 the area in which the source is located. The Maryland Department of  
22 the Environment (MDE) prefers in-State sources of offsets. However,  
23 offsets may come from other emissions sources outside of Maryland  
24 that are in the same or higher ozone nonattainment classification area,  
25 and that are located in the broad vicinity of the proposed new source.

26 **Q. HAS CATOCTIN POWER SECURED SUFFICIENT NO<sub>x</sub> AND VOC**  
27 **OFFSETS AT THIS TIME?**

28 A. No.

29 **Q. BY WHAT TIME IS CATOCTIN POWER REQUIRED TO SECURE**  
30 **THE NO<sub>x</sub> OFFSETS?**

1 A. Catoctin Power must demonstrate to ARMA’s satisfaction that the  
2 appropriate number of offsets from an acceptable source or sources are  
3 secured before air quality approvals can be issued.

4 **Q. ARE ALL OTHER SOURCES IN THE STATE OWNED BY**  
5 **CATOCTIN POWER COMPLYING WITH ALL APPLICABLE**  
6 **CLEAN AIR ACT REQUIREMENTS?**

7 A. Catoctin Power and its parent company Sempra Energy Resources do  
8 not own or operate any other air emissions sources in the State of  
9 Maryland.

10 **Q. IS THE STATE SATISFIED WITH THE APPLICANT’S**  
11 **ALTERNATIVE’S ANALYSIS FOR THIS PROJECT?**

12 A. As a major source of NO<sub>x</sub> and VOCs under NA-NSR, Catoctin Power  
13 is required to conduct “...an analysis of alternative sites, sizes,  
14 production processes, and environmental control techniques for a  
15 proposed source [that] demonstrates that benefits of the proposed  
16 source significantly outweigh the environmental and social costs  
17 imposed as a result of its location, construction, or modification” under  
18 COMAR 26.11.17.03B(6).

19 ARMA believes that the information presented by Catoctin Power in its  
20 CPCN application, particularly Section 1-4 (“Siting Considerations”) is  
21 sufficient for this purpose and that the project is acceptable on these  
22 terms.

23 *Federal and State Applicable Requirements (Other than PSD and NA-NSR*  
24 *and Related Requirements)*

25 **Q. BESIDES PSD, ARE THERE OTHER FEDERAL AIR**  
26 **REGULATIONS TO WHICH THE PROPOSED PROJECT WILL BE**  
27 **SUBJECT?**

28 A. Yes. The CTs will be subject to New Source Performance Standards  
29 (NSPS) Subpart GG “ Standards of Performance for Stationary Gas

1 Turbines” (in 40 CFR 60 Subpart GG). The duct burners will be subject  
2 to NSPS Subpart Da “Standards of Performance for Electric Utility  
3 Steam Generating Units for which Construction is Commenced after  
4 September 18, 1978” (40 CFR 60 Subpart Da). The project is also  
5 subject to the Acid Rain provisions of Title IV of the Clean Air Act (40  
6 CFR Parts 72 and 75). Additionally, the facility will be required to  
7 obtain a Title V operating permit.

8 **Q. DID CATOCTIN POWER ADDRESS COMPLIANCE WITH THE**  
9 **REQUIREMENTS IN THE PREVIOUS QUESTION TO YOUR**  
10 **SATISFACTION?**

11 A. Yes. The applicant addressed compliance with the requirements in the  
12 previous question in its CPCN application and subsequent responses  
13 to Data Requests.

14 **Q. ARE THERE OTHER STATE AIR REGULATIONS TO WHICH THE**  
15 **PROPOSED PROJECT WILL BE SUBJECT?**

16 A. Yes. Each of the proposed new sources will be subject to various State  
17 emissions requirements, including, but not limited to, restrictions on  
18 PM and opacity, and on the sulfur content of the fuel. The facility will  
19 be subject to MDE’s NO<sub>x</sub> Reduction and Trading Program regulations,  
20 which prohibit NO<sub>x</sub> emissions during the ozone season in excess of the  
21 allocated amount of NO<sub>x</sub> (COMAR 26.11.29 and 30). The facility will  
22 also be subject to various recordkeeping and reporting requirements,  
23 and will be required to obtain a State Operating Permit.

24 **Q. HAS CATOCTIN POWER ADDRESSED COMPLIANCE WITH**  
25 **APPLICABLE STATE REGULATIONS TO YOUR SATISFACTION?**

26 A. Yes, except that they have not yet identified the source of NO<sub>x</sub> and  
27 VOC offsets.

28 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

29 A. Yes it does.

*Appendix A*

*Statement of Qualifications*

**APPENDIX A**  
**STATEMENT OF QUALIFICATIONS FOR**  
**WILLIAM PAUL**

**Air Quality Permits Manager**

**EDUCATION:**

B.S. Chemical Engineering, 1975, Lehigh University, Bethlehem, Pa.  
Masters, Business Administration, 1982, Loyola College, Baltimore, Md.  
Masters, Environmental Policy, University of MD College Park, pending.

**PROFESSIONAL BACKGROUND:**

As Chief of the Combustion and Metallurgical Division, Air Quality Permits Program of the Maryland Department of the Environment, Mr. Paul has acquired more than 25 years of experience in air pollution control and the permitting of major stationary sources. This includes 19 years with MDE and 10 years in the private sector designing and marketing air pollution control equipment. As a Division Chief, he has primary responsibility for overseeing air quality application reviews of major stationary sources subject to Prevention of Significant Deterioration (PSD) and non-attainment New Source Review (NSR). In the past several years, Mr. Paul has been extensively involved in permitting the following electric generating stations and independent power producers in Maryland: Old Dominion Electric Cooperative's Rock Springs, Orion Power's Kelson Ridge, PEPCO Station H, PEPCO Chalk Point, Southern Maryland Electric Cooperative (SMECO), BGE Perryman, AES Warrior Run, Panda Brandywine, Montgomery County Resource Recovery Facility, and the Town of Berlin. These projects have involved a detailed assessment of ambient air quality impacts, the application

of best available air pollution control measures and ensuring the inclusion of all applicable federal and state air quality control requirements.